

Town of Amherst
Police Station Design & Build
Addendum #2

Based on keeping the existing side door into the officer side, will the office size on the front wall decrease to extend the hallway to the door? **Yes, the office will need to be smaller to accommodate leaving the side door. We do want the side door to be replaced with a single steel door.**

Will a sprinkler system be required? **Not required by Building Code.**

Will a fire alarm system be required? **Only if required by Building Code.**

Is the existing bathroom located next to the proposed Kitchen/Break Room? **Yes**

Exterior walls: Furred out for insulation and electrical rough-in, or paint existing block? **Contractor will simple paint existing block.**

Interior walls: 2x4 wood framing to roof joists, drywall
Sound insulation in all walls? **Sound insulation only needs to be in interview room.**

Exterior Doors

Front door: single, insulated hollow metal door and frame? **Single glass door with side lights on each side. No ballistics but needs to have window film.**

Glass: half or full? bullet-proof?

Frame existing opening, exterior finish: EIFS

Interior Doors

Solid core flush wood doors and hollow metal frames? **All solid wood doors. Door between office space and lobby needs to be outside steel door.**

Offices, Interview Room and Conference Room: half glass?

Interior Window

Lobby to Secretary: bullet proof glass? **No ballistics but window film**

Door Hardware: Lever-type ADA-compliant. **Yes**

Ceilings

2x4 acoustical tile, square edge, T-grid system? **Yes**

Flooring

Vinyl composition tile: Lobby, Hallway, Toilets, Break Room, Storage

Carpet tiles: Offices, Secretary, Conference Room **Carpet only in conference room.**

Light fixtures

2x4 LED recessed troffer **Yes**

Conference Room: dimmers? **Yes**

Electrical

Receptacles per code **Yes**

Fiber? **Run conduit in so wiring can be ran later.**

HVAC

Heat Pump

Gas or Propane? **Heat Pump**