Town of Amherst Invitation For Bid #2024-05 Addendum #2

1) Height of Waughs Ferry and Union Hill water tanks.

Waugh's Ferry if 50 feet and Union Hill is 20 feet

- 2) Are all address associated with the zip code, 24521?
 - Yes. All address provided are Amherst, VA. 24521
- 3) A full list of addresses and Town maps are now posted with the RFP.
- 4) There is a correction in the number of 2" meters. We have seventeen 2" meters, not 34 as originally indicated on the questionnaire.
- 5) Regarding the 2" meters, I've been told they are all in setters with a by-pass, can the town provide the lay length of the meters? Either 17" or 15-1/4".
 - There are two 15-1/4" and fifteen 17".
- 6) In section V Delivery and Storage: Is the Town the owner of the storage area?
 Yes, the Town owns the storage area.
- 7) What type of meter box lids do you currently have? Concrete, metal, composite?

We have 919 metal and 241 plastic. We also have 5 aluminum vaults and 2 concrete vaults.